

CITY OF MOUNTAIN VIEW

SFUND RECORDS CTR
2807-92022

SFUND RECORDS CTR
88172193

Public Works
(415) 966-6311

January 14, 1982

Mr. Greg Geary
Fairchild Camera and Instrument Corporation
369 Whisman Road
Mail Stop 19-105
Mountain View, CA 94043

Dear Mr. Geary:

INDUSTRIAL WASTE VIOLATIONS

The following industrial waste discharge violations are called to your attention for action:

<u>DATE</u>	<u>LOCATION</u>	<u>CONSTITUENT</u>	<u>EFFLUENT CONCENTRATION MG/L</u>	<u>ORDINANCE LIMIT MG/L</u>
Dec. 1, 1981	Building 20	Fluoride	9.5	5.0
Dec. 16, 1981	Buildings 3 & 4	Fluoride	8.2	5.0

As discussed with you on January 7, 1982 at your plant, we request that the results of your self-monitoring at these locations be sent to me on a weekly basis until three consecutive samples show compliance with the City's Industrial Waste Ordinance. Weekly sampling must cover at least one 24-hour work period per week and must be analyzed by a laboratory certified for chemical testing by the State Department of Health Services.

If compliance cannot be achieved immediately under your current process control, a letter must be sent to me by January 29, 1982 giving your schedule for achieving full compliance and listing the interim steps that you plan to take to reduce mass emissions until compliance is achieved. Failure to take diligent action to correct the above violations will result in suspension of Fairchild's industrial waste discharge permit.

If you have any questions, please call me at 966-6329.

Sincerely,

Norman H. Lougee
Water Division Engineer

MHL/X/Th-B6

cc: Mr. Steve Hayashi

Mr. Ash Chapman

CM, DM, CA